

Certificate

Registration No.: PV 50199626

Page 1

Report No.: 15040048.001

License Holder:

Jiangsu SunLink PV Technology Co., Ltd.
Nanyuan Road, Zhangjiagang Economic
Development Zone,
215600, Zhangjiagang City,
Jiangsu,
P.R. China

Product:

PV Module

Type:

With 72 cells of 6" mono c-Si:
SL280-24Mxxx (xxx=260-315, in increment of 5)
With 60 cells of 6" mono c-Si:
SL220-20Mxxx (xxx=215-260, in increment of 5)
With 54 cells of 6" mono c-Si:
SL200-18Mxxx (xxx=195-235, in increment of 5)
With 36 cells of 6" mono c-Si:
SL110-12Mxxx (xxx=130-155, in increment of 5)
With 72 cells of 6" poly c-Si:
SL280-24Pxxx (xxx=255-310, in increment of 5)
With 60 cells of 6" poly c-Si:
SL220-20Pxxx (xxx=210-255, in increment of 5)
With 54 cells of 6" poly c-Si:
SL200-18Pxxx (xxx=190-230, in increment of 5)
With 36 cells of 6" poly c-Si:
SL110-12Pxxx (xxx=125-155, in increment of 5)
With 72 cells of 5" mono c-Si:
SL180-24Mxxx (xxx=170-205, in increment of 5)
With 36 cells of 5" mono c-Si:
SL080-12Mxxx (xxx=085-100, in increment of 5)

Manufacturing Plant:

Jiangsu SunLink PV Technology Co., Ltd.
Nanyuan Road, Zhangjiagang Economic
Development Zone,
215600, Zhangjiagang City,
Jiangsu,
P.R. China

Basis:

- IEC 61730-1:2004
 - IEC 61730-2:2004
 - EN 61730-1:2007
 - EN 61730-2:2007
- "Photovoltaic (PV) module safety qualification"

Factory Inspection

To document the consistent quality of the product factory inspections are performed periodically.

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to **1000 VDC**.
- The fire test (IEC 61730-2 / MST 23) was not performed.
- The details of the factory inspection are documented in report no. 15040440.001.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 21 March 2016.



- Qualified, IEC 61215
- Safety tested, IEC 61730
- Periodic inspection

Shanghai, 22 March 2011

Certification body

Dipl.-Ing. Bernd Scheirer